

ELIGIBLE MEASURES and ACCESSORIES

Home Performance with ENERGY STAR® is designed to transform the way energy efficiency services are delivered to existing 1 - 4 family homes. To qualify for rebates and financing options offered through the Program, the energy efficiency improvements must be evaluated through a comprehensive Home Assessment and installed by a contractor participating in the Home Performance with ENERGY STAR program, and meet the minimum efficiency requirements listed below.

Customer rebates are based on the type of fuel used for space heating. Rebates include both primary and supplemental measures and are capped, per residential unit, at \$3,000. Homes heated with Natural Gas will be referred to National Grid's Enhanced Air Sealing Program.

I. Primary Measures and Rebates:

Homes Heated with Electricity (Primary) Initial assessment and recommendations must be made through Home Performance Direct and include fixed pricing for applicable measures.	75% for insulation, air-sealing, duct sealing. Installation of one new ventilation system and/or repair/upgrade of multiple existing venting systems (IF conducted in association with air/duct sealing and/or insulation upgrades) †
Homes heated with oil or propane with central air conditioning systems.	25% for insulation, air-sealing, duct sealing. Installation of one new ventilation system, and/or repair/upgrade of multiple existing venting systems (IF conducted in association with air/duct sealing and/or insulation upgrades)
Homes Heated with Natural Gas	Referral to National Grid Enhanced Air Sealing Program 1-800-860-0815
Primary Measures	Minimum Efficiency Requirements
Insulation (attic, wall, floor, band/ rim joist, basement, crawlspace, and overhang).	NYS Energy Conservation Code compliant
Air-sealing	Documented reduction of at least 10% cfm50 based on pre- and post-blower door test results.
Duct Sealing (ONLY for Central Air Conditioning or Heat Pump ducts located in an attic, crawl space or other unconditioned area.)	Documented reduction of at least 10% of cfm flow based on approved diagnostic methodology. Sheet metal and flexible ductwork must be sealed at all duct connections using UL 181B Mastic or similar UL-approved products designed for sealing ducts. Aluminum FSK tape may be used on duct-board systems.
Installation of one new ventilation system and/or repair/upgrade of multiple existing venting systems (If required to facilitate air-sealing, maximum \$400 ventilation incentive)	Exhaust fan must be ENERGY STAR Qualified <u>and include an automatic control</u> ; for repairs and replacements, system must be capable of delivering adequate airflow as per ASHRAE 62-89

†Must go through the Home Performance Direct program in order to qualify. Rebates will apply to eligible recommendations made as part of the additional weatherization work. Please call 1-877-ESTAR-LI for more program information.

II. Supplemental Measures and Rebates:

Home Criteria
Homes Heated with Electricity (Primary)
Oil or propane Heat with CAC
Homes heated with Natural Gas (<i>Referral to National Grid Enhanced Air Sealing Program</i>)

Supplemental Measures	Minimum Efficiency Requirements	Supplemental Incentives
Replacement Windows	NFRC-rated SHGC .44 AND U-value of .35, or lower. (ALL windows must be located in a exterior adjacent to conditioned space	\$35 per window (excludes patio doors)
Storm windows/Storm doors	No minimum efficiency requirement; If storm window is to be applied to sliding window, interior storm application is required.	\$10 per unit
Measures to provide sufficient <u>combustion air</u> and prevent Combustion Appliance Zone (CAZ) depressurization, spillage or inadequate draft	Allowed when BPI-required combustion safety tests indicate problem(s) with CAZ depressurization, draft or spillage, per BPI standards	\$50 toward the installed cost if conducted in association with air/duct sealing and/or insulation upgrades
Upgrade of knob and tube wiring in order to install insulation	Meet all applicable codes	\$50 toward the installed cost if conducted in association with air/duct sealing and/or insulation upgrades
Thru the Wall Room Air Conditioner (must be combined with at least 1 major measure installed by the contractor, such as air sealing, insulation, or water heater)	CEE Tier 2; installation must be tightly sealed and confirmed by blower door test. Refer to CEE website: www.cee1.org	\$25 toward the installed cost
Electric Water Heater	Only for replacement of existing electric water heater. EF .93	\$150 toward the installed cost