

COOL HOMES REBATE SCHEDULE

2011 Customer Energy Efficient Equipment Installation Incentive*			
Tier	Eligible Equipment	Efficiency Requirements	Customer Incentive
1. New/Replacement	a) Split Central Air Conditioners b) Air Source Heat Pumps c) Ductless Mini Split Systems	a) SEER \geq 14.5 and EER \geq 12.0 b) SEER \geq 14.5 and EER \geq 12.0 and HSPF \geq 8.2 c) SEER \geq 14.5 and EER \geq 11.5	\$250/unit
2. New/Replacement	a) Split Central Air Conditioners b) Air Source Heat Pumps c) Ductless Mini Split Systems	a) SEER \geq 15 and EER \geq 12.5 b) SEER \geq 15 and EER \geq 12.5 and HSPF \geq 8.5 c) SEER \geq 15 and EER \geq 12	\$300/unit
3. New/Replacement	a) Split Central Air Conditioners b) Air Source Heat Pumps c) Ductless Mini Split Systems	a) SEER \geq 16 and EER \geq 13 b) SEER \geq 16 and EER \geq 13 and HSPF \geq 8.5 c) SEER \geq 16 and EER \geq 12.5	\$400/unit

*Customers may earn one incentive per unit based on the highest Tier for which the unit will qualify

EARLY RETIREMENT REBATE SCHEDULE

2011 Customer Energy Efficient Equipment Installation Incentive*			
Tier	Eligible Equipment	Efficiency Requirements	Customer Incentive
1. Early Retirement	a) Split Central Air Conditioners b) Air Source Heat Pumps	a) SEER \geq 14.5 and EER \geq 12.0 b) SEER \geq 14.5 and EER \geq 12.0 and HSPF \geq 8.2	\$500/unit
2. Early Retirement	a) Split Central Air Conditioners b) Air Source Heat Pumps	a) SEER \geq 15 and EER \geq 12.5 b) SEER \geq 15 and EER \geq 12.5 and HSPF \geq 8.5	\$600/unit
3. Early Retirement	a) Split Central Air Conditioners b) Air Source Heat Pumps	a) SEER \geq 16 and EER \geq 13 b) SEER \geq 16 and EER \geq 13 and HSPF \geq 8.5	\$700/unit

*Customers may earn one incentive per unit based on the highest Tier for which the unit will qualify

To qualify for an Early Retirement rebate, the CAC or Heat Pump equipment *being replaced* must either be operational or, if non-operational, less than 20 years old and repairable for less than \$1,000.

Rebate Qualifications

1. You must currently be a LIPA residential customer.

2. Your Contractor must be a Cool Homes Participating Contractor

To be eligible to participate in LIPA's 2011 Cool Homes rebate program, your contractor must be a Cool Homes Participating Contractor. Please visit our Web site at www.lipower.org to see a list of participating contractors.

3. Units must be correctly sized for your home:

Over-sizing of residential cooling equipment causes poor equipment performance and excessive energy consumption, particularly during times of peak electricity demand.

All Air Conditioners and Heat Pumps must be sized based on ACCA Manual J version 8.0 calculations.

4. Units must have proper airflow and system charging

Improper refrigerant charge and system airflow can significantly reduce both the performance and energy efficiency of central cooling equipment. Your participating Cool Homes contractor will test to ensure your system has the correct refrigerant charge and airflow.

