

**Long Island Power Authority**

**Statement Of Long Island Choice (LIC) Parameters**

**Installed Capacity Reserve Requirements; Locational Installed Capacity (Locational ICAP) Requirements**

Applicable to all Load Serving Entities (LSE's) in accordance with NYISO requirements  
As set forth in the Tariff for Electric Service

**Installed Capacity Reserve Requirements**

Each LSE will be required to provide Installed Reserve Capacity equal to 119.60% Installed Capacity (ICAP) or 108.94% Unforced Capacity (UCAP) of their customers' total base load plus Long Island line losses and off island line losses.

**Locational Installed Capacity (Locational ICAP) Requirements**

A portion of each LSE's total load requirements must be provided by resources that qualify as local to Long Island. The Locational Installed Capacity requirement is equal to 99.50% ICAP or 89.24% UCAP of each LSE's base load plus Long Island line losses.