# LIPA's Integrated Resource Plan Public Comment Session



## AGENDA





### Welcome and thank you for attending our Integrated Resource Plan public comment session!

- We encourage and request public participation and feedback in our integrated resource planning process.
- Today's session is one part of an ongoing conversation. We encourage you to stay engaged, reach out with further comments or questions, and participate in future discussions.
- All public comments will be taken into consideration by the LIPA Board of Trustees.





## MEET THE TEAMS

### Long Island Power Authority

### **PSEG Long Island**

**Thomas Falcone** *Chief Executive Officer* 

Gary Stephenson Senior Vice President of Power Supply

**Tom Simpson** *Director of Power Supply Planning*  Yuri Fishman Director, Power Resources and Contract Management

Lucyna Khazanovich Director, Strategy and Planning

**Peter Andolena** *Manager, Capacity Markets and Regulatory Policy* 



## ABOUT LIPA

- LIPA is the third-largest not-for-profit public power utility in the U.S.
- LIPA owns the electric transmission and distribution system that provides electrical service to customers on Long Island and the Rockaways.
- Since 2014, LIPA has contracted with PSEG Long Island for management services, and LIPA provides service under the PSEG Long Island brand name.

Fast Facts		
Customers	1.2 million	
Service Territory	Long Island and the Rockaway Peninsula	
Energy Requirements	19.8 million MWH	
Generating Capacity	~5,500 Megawatts	
Distribution System	14,000 miles	
Transmission System	1,400 miles	
2024 Operating Budget	\$4.3 billion	
2024 Capital Budget	\$905 million	



## LONG ISLAND AND ROCKAWAYS ELECTRIC GRID

- LIPA's service territory spans Nassau and Suffolk Counties in Long Island and the Rockaway Peninsula in Queens County.
- Much of Long Island is interconnected for reliability and commercial purposes, forming a redundant, resilient network that is planned, controlled, and operated centrally by the local utility and the New York State Independent System Operator (NYISO).





## WHAT IS AN INTEGRATED RESOURCE PLAN?

- An Integrated Resource Plan (IRP) studies the supply-side (i.e., generation, energy storage), demand-side (i.e., energy efficiency, demand response, distributed energy resources), and transmission investments that LIPA may need to make over the next 10 to 20 years to provide clean, reliable, cost-effective service to customers under a range of scenarios.
- LIPA's last IRP was released in 2017 and determined that LIPA would not need to add generation to meet load growth through at least 2035, mainly due to increased energy efficiency and renewable energy. The decision was made to forego new or repowered fossil-fueled generation and instead concentrate on a clean energy future.
- An IRP considers customer usage trends, existing resources, policy and regulatory requirements, changing technology, risks, and opportunities, among other factors.





**IRP Summary Guide** 





## NAVIGATING THE IRP SUMMARY GUIDE

- LIPA has organized the findings of the Integrated Resource Plan (IRP) around themes in the form of answers to frequently questions to help customers and stakeholders understand the plan's assumptions, findings, and next steps.
- The IRP Summary Guide can be viewed and downloaded on an online, interactive flipbook on the LIPA website.
- Physical copies are available at the public comment sessions or you can view the digital version by scanning the QR code.



**IRP Summary Guide** 



## PUBLIC OUTREACH: EDUCATIONAL VIDEO SERIES

- LIPA has created and published an IRP educational video series on various topics, including:
  - Part I: What is an Integrated Resource Plan?
  - Part II: Offshore Wind

DA

- Part III: <u>Decarbonizing the Electric Grid</u>
- Part IV: <u>Electrification Maintaining Reliability</u>
  <u>and Affordability</u>

ΤK

 The series can be viewed on LIPA's <u>LinkedIn</u> <u>company profile</u> and through <u>email campaigns</u>.



## WHO CONDUCTED THE IRP?

- LIPA's resource planning process is a collaborative effort, developed by LIPA's service provider, PSEG Long Island, with active involvement from LIPA staff and assistance from utility consultants and industry researchers, who provided input on emerging technologies such as advanced battery storage, including short- and long-term feasibility as well as risks and challenges to consider in model development.
- LIPA would like to recognize the valuable contributions provided by:





## NEW YORK STATE'S CLIMATE ACT GOALS

- In 2019, New York's Climate Act established goals for economywide carbon reduction and clean resource additions.
- LIPA's 2023 IRP aims to provide an action plan through 2030 to meet interim milestones established in the Climate Act, while framing resource decisions that will need to be made later to achieve 100% zero-emission electricity by 2040.



### Figure 1: New York's Climate Act Goals

IRP Summary Guide Reference – Executive Summary: Page 17

## WHAT SCENARIOS ARE MODELED IN THE IRP?

- The IRP's recommendations are based on scenario modeling that assesses the impacts of planning uncertainties and considers alternative solutions to achieve Climate Act targets while satisfying system reliability requirements.
- The starting point for the scenarios is a base case that includes the clean resource objectives in the Climate Act and follows trajectories for renewable energy development and beneficial electrification of heating and transportation similar to those detailed in the Scoping Plan produced by the New York Climate Action Council.
- Besides the base case, the following additional scenarios were assessed in the IRP:
  - Accelerated economywide decarbonization
  - Expanded interties from Long Island to other regions
  - Accelerated transition away from fossil fuel combustion
  - Expanded demand-side measures
  - Advanced technologies



- LIPA's power supply is sourced from:
  - LIPA's 250-megawatt (MW) share of Nine Mile Point nuclear unit #2, plus energy from FitzPatrick nuclear
  - A power supply contract with National Grid for 3,550 MW
  - Contracts with other on-island providers for 1,750 MW
  - Purchases from electric markets in New York, New England, and the mid-Atlantic states
- Generation and imports must be controlled to match customer demand minute-by-minute.
- The most efficient or economical power plants run all day long and are known as "baseload plants."
- Smaller generating plants that can be started up quickly, but with higher operating costs, are run only to meet the peak loads of each day – these are known as "peakers."



### Figure 4: Sources of Long Island Energy Production in 2022



- 1. By 2030, the addition of solar and offshore wind resources will cause LIPA's carbon footprint to decline by over 70% from 2010 levels.
- LIPA and New York State are taking actions on both the demand- and supply sides to achieve a zero-carbon electric grid.
- Clean energy resources under development will add thousands of megawatts of new clean resources to the Long Island and Rockaways electric grid by the early 2030s.
- Projects in development include:
  - 1,419 MW of customer-owned solar and local solar farms
  - 2,368 MW of offshore wind
  - 750 MW of battery storage

### Figure 5: Long Island Clean Energy Projects in Service by the Early 2030s

<b>Solar</b> (1,419 MW)	Size (MW <sub>AC</sub> )	In-Service (Est./Act.)
Long Island Solar Farm	32	2011
Eastern Long Island Solar Project	11	2013
Shoreham Solar Commons	25	2018
Riverhead Solar	20	2019
Kings Park Solar 1 and 2	4	2019
Solar Feed-in Tariffs I-III	89	2021-2022
LI Solar Calverton	23	2021
Behind-the-Meter	1,200	2030
Solar Communities (FIT V)	15	2025
Offshore Wind (2,368 MW)	Size (MW <sub>AC</sub> )	In-Service (Est./Act.)
Offshore Wind (2,368 MW) South Fork Wind Farm	<b>Size</b> (MW <sub>AC</sub> ) 130	In-Service (Est./Act.) Early 2024
Offshore Wind (2,368 MW) South Fork Wind Farm Sunrise Wind	<b>Size</b> (MW <sub>AC</sub> ) 130 924	In-Service (Est./Act.) Early 2024 Mid-to-Late 2020s
Offshore Wind (2,368 MW) South Fork Wind Farm Sunrise Wind Excelsior Wind	Size (MW <sub>AC</sub> ) 130 924 1,314	In-Service (Est./Act.) Early 2024 Mid-to-Late 2020s 2030s
Offshore Wind (2,368 MW) South Fork Wind Farm Sunrise Wind Excelsior Wind Energy Storage (750 MW)	Size (MW <sub>AC</sub> ) 130 924 1,314 Size (MW <sub>AC</sub> )	In-Service (Est./Act.) Early 2024 Mid-to-Late 2020s 2030s In-Service (Est./Act.)
Offshore Wind (2,368 MW) South Fork Wind Farm Sunrise Wind Excelsior Wind Energy Storage (750 MW) East Hampton & Montauk Storage	Size (MW <sub>AC</sub> ) 130 924 1,314 Size (MW <sub>AC</sub> ) 10	In-Service (Est./Act.)        Early 2024        Mid-to-Late 2020s        2030s        In-Service (Est./Act.)        2018 & 2019
Offshore Wind (2,368 MW) South Fork Wind Farm Sunrise Wind Excelsior Wind Energy Storage (750 MW) East Hampton & Montauk Storage 2023 RFP Awards (Pending)	Size (MW <sub>AC</sub> ) 130 924 1,314 Size (MW <sub>AC</sub> ) 10 175+	In-Service (Est./Act.)        Early 2024        Mid-to-Late 2020s        2030s        In-Service (Est./Act.)        2018 & 2019        2025
Offshore Wind (2,368 MW) South Fork Wind Farm Sunrise Wind Excelsior Wind Energy Storage (750 MW) East Hampton & Montauk Storage 2023 RFP Awards (Pending) Future Storage Additions	Size (MW <sub>AC</sub> ) 130 924 1,314 Size (MW <sub>AC</sub> ) 10 175+ 565	In-Service (Est./Act.)        Early 2024        Mid-to-Late 2020s        2030s        In-Service (Est./Act.)        2018 & 2019        2025        2030



- 1. By 2030, the addition of solar and offshore wind resources will cause LIPA's carbon footprint to decline by over 70% from 2010 levels.
  - By 2030, nearly half of the power supply to Long Island will be sourced from offshore wind, with an additional 19% from zero-carbon solar and nuclear.





- 1. By 2030, the addition of solar and offshore wind resources will cause LIPA's carbon footprint to decline by over 70% from 2010 levels.
- Long Island's clean energy portfolio is expected to total about 5,800 MW by 2030, compared to the 2023 peak demand of approximately 5,000 MW.
- Some fossil fuel generation will be needed to serve as backup to intermittent generation until new technologies for long-duration, dispatchable, emissions-free resources become available at scale.
- This fossil generation will run less, serving to balance renewables, so the carbon emissions of the Long Island grid will decline steeply.

### Figure 7: Carbon Emissions Footprint for LIPA's Power Supply from 2010 to 2030





2. Offshore wind projects already under development will connect 2,400 megawatts to the Long Island grid, out of a statewide goal of 9,000 MW by 2035, with more to come as forecasts show as much as 18,000 MW or 18 gigawatts of offshore wind by 2050.

### Figure 12: Current Procurements for Offshore Wind Development | 3,600 MW of Offshore Wind to Connect to Long Island



### Figure 13: Contracted New York Offshore Wind Projects

Project Name	Owner	Size (MW)	Contract Off-Taker	Contract Award Date	Interconnect Utility	In-Service Date
South Fork Wind	Ørsted and Eversource	130 MW	LIPA	2017	LIPA	Early 2024
Sunrise Wind	Ørsted and Eversource	924 MW	NYSERDA	2019	LIPA	Mid-to-Late 2020s
Beacon Wind	Equinor Wind US LLC	1,230 MW	NYSERDA	2021	Con Edison	Late 2020s
Attentive Energy One	TotalEnergies, Rise Light & Power, Corio Generation	1,404 MW	NYSERDA	2023	Con Edison	2030s
Community Offshore Wind	RWE Offshore Renewables and National Grid Ventures	1,314 MW	NYSERDA	2023	Con Edison	2030s
Excelsior Wind	Vineyard Offshore	1,314 MW	NYSERDA	2023	LIPA	2030s

- 2. Offshore wind projects already under development will connect 3,600 megawatts to the Long Island grid, out of a statewide goal of 9,000 MW by 2035, with more to come as forecasts show as much as 18,000 MW or 18 gigawatts of offshore wind by 2050.
- Back in 2017, the LIPA Board of Trustees approved a power purchase agreement to buy energy from South Fork Wind – the first agreement of its kind in the nation at the time.
- The wind farm will consist of 12 turbines, 5 of which are already complete, and the entire offshore wind project should be finished in early 2024.





- 3. Long Island's high-voltage transmission grid will need to be built out to integrate the large amounts of offshore wind, some of which will be exported to the rest of New York. The Propel NY Energy project will meet these transmission needs through 2030 and beyond, although further study is required to assess transmission needs for a zero-carbon electric grid by 2040.
- In 2020, LIPA and Con Edison conducted technical studies to assess the need for system expansion and recommended to the PSC that additional transmission cables would be needed to enable the transmission of offshore wind from Long Island.
- In 2021, the PSC declared a Public Policy Transmission Need and directed the NYISO to procure the necessary transmission development, with costs to be shared by electric customers statewide.
- The Propel NY Energy project was selected by the NYISO in June of 2023 and will include:
  - Three new high-voltage cables from Long Island to New York City and Westchester.
  - Capacity to handle the full output of 3,000 MW of offshore wind interconnected to Long Island without curtailment.
  - Corresponding increases in transfer capability between Long Island and the rest of the state for the import and export of energy, with improved system operational flexibility.







- 4. As offshore wind and battery storage resources come online, LIPA will be able to retire up to 800 MW of existing Long Island power plants by 2030.
  - As new clean energy sources are added to the grid, LIPA will ramp down its fossil fuel power purchase agreements.
  - Contracts for selected units will be extended into the 2030s to support system operating flexibility and reliability, balance the intermittency of renewables and serve as backup during lulls in offshore wind production and when the sun goes down.
  - Nearly all of LIPA's power purchase agreements are subject to renewal by 2030, so the portfolio can be reshaped based on need.



### Figure 8: Phase-Out of Fossil Fuel Power Contracts

- 4. As offshore wind and battery storage resources come online, LIPA will be able to retire up to 800 MW of existing Long Island power plants by 2030.
  - LIPA's single largest fossil fuel purchase agreement is the Power Supply Agreement (PSA) with National Grid Genco for 3,550 MW of Long Island Lighting Company-era legacy generation.
  - Under the PSA, LIPA has the right to cease purchasing electricity from selected units before the contract's expiration in April 2028. LIPA has retired 420 MW to date, with around 200 MW of additional combustion turbine retirements pending.
  - The exact order, amount, and timing of steam turbine retirements has not yet been determined and will depend on new resources being interconnected to the grid.

<b>Retired Unit</b>	Technology	Size (MW)	<b>Retirement Date</b>
E.F. Barrett Gas Turbine ("GT") #7 (Island Park)	Gas Turbine	18	2011
Far Rockaway	Steam	100	2012
Glenwood Landing	Steam	228	2012
Montauk Diesels 2 to 4	Diesel	6	2013

Figure 9: Phase-Out of Fossil Fuel Power Contracts

Planned Near-Term Retirements	Technology	Size (MW)	<b>Retirement Date</b>
Shoreham GT #1 and #2	Gas Turbine	71.5	2025
Glenwood GT #1	Gas Turbine	15	2025
Glenwood GT #3	Gas Turbine	55	2025
West Babylon GT #4	Gas Turbine	52	2025
E.F. Barrett (Island Park)	Steam Turbine	188-376	by 2030
Port Jefferson	Steam Turbine	188-376	by 2030
Northport	Steam Turbine	up to 387	by 2030

Note: The exact order, amount, and timing of steam turbine retirements to be determined.

- 4. As offshore wind and battery storage resources come online, LIPA will be able to retire up to 800 MW of existing Long Island power plants by 2030.
  - Capacity factors are the ratio of annual electric energy production as compared to the theoretical maximum.
  - New baseload power plants typically need to run at capacity factors in excess of 70% to be economic.
  - LILCO-era steam turbines are no longer operating as intended, albeit are well maintained and have been in service for 50-70+ years.
  - While each plan ran around a 50%+ capacity factor in the 1990s, the production has declined sharply in recent years and is projected to further decline.



### Figure 10: Long Island Has Become Less Dependent on Steam Turbines for Baseload Generation



- 5. Demand-side measures, such as LIPA's energy efficiency rebate programs and customer installations of solar photovoltaic systems, are projected to effectively offset economy-driven growth in electricity sales between now and 2030.
- Electricity sales are expected to remain steady through 2030 as energy efficiency and rooftop solar continue to moderate growth driven by the economy
  - Energy efficiency and demand-side management are crucial to achieving New York's objective of an 85% reduction in economywide GHG emissions by 2050.
  - The Climate Act requires 185 trillion Btu of energy efficient savings by 2025.
  - LIPA spends ~\$90 million annually on EE programs that incentivize customers to save energy.
  - Long Island is on track to exceed its 1,300 MW share of the statewide 10,000 MW solar goal for 2030.
- Electrification of transportation and heating will result in significant load growth post-2030.





IRP Summary Guide Reference – Electrification and Electricity Sales Through 2040: Page 55

### IRP Summary Guide Reference – Electrification of Transportation and Heating: Page 51

## WHAT ARE THE KEY FINDINGS OF THE IRP?

- 5. Demand-side measures, such as LIPA's energy efficiency rebate programs and customer installations of solar photovoltaic systems, are projected to effectively offset economy-driven growth in electricity sales between now and 2030.
  - Buildings and transportation produce the majority of New York's carbon emissions.
  - LIPA's 2024 budget funds initiatives to reduce Long Island's carbon footprint, including the electrification of transportation and heat and hot water in buildings and homes.





- Cold climate heat pumps can help customers save on both carbon and money for both oil heat and new construction.
- LIPA is leveraging our customer insights, relationships, and contractor network to accelerate heat pump adoption.



### Figure 24: Long Island Homes Heat with Oil at Ten Times the National Average

### Figure 25: Heat Pumps Save Money and Carbon for Oil Heat

Existing Building - Oil Burner	Buy New Central Air Conditioning	Buying New Air-Source Heat Pump
Upfront Cost	\$7,278	\$16,687
LIPA Rebate*	-	(\$5,383)
Federal Tax Credit*	-	(\$2,000)
Net Cost	\$7,278	\$9,304
Annual Home Heat Bill	\$3,824	\$1,487
Annual Savings	-	\$2,336
Payback Period	-	0.9 years
Carbon Footprint from Heating (2022)	-	-46%
Carbon Footprint from Heating (2040)	-	-100%

### Figure 26: Heat Pumps Save Money and Carbon for New Construction

New Construction - Gas Furnace	Buy New Central Air Conditioning + Gas Furnace	Buying New Air-Source Heat Pump
Upfront Cost	\$14,080	\$16,687
LIPA Rebate*	-	(\$5,383)
Federal Tax Credit*	-	(\$2,000)
Net Cost	\$14,080	\$9,304
Annual Home Heat Bill	\$2,366	\$1,435
Annual Savings	-	\$931
Payback Period	-	Immediate
Carbon Footprint from Heating (2022)	-	-25%
Carbon Footprint from Heating (2040)	-	-100%



IRP Summary Guide Reference – Electrification of Transportation and Heating: Pages 53-54

- 6. LIPA's transition to TOD rates in 2024 and 2025 will encourage customers to shift energy use outside of peak hours and thereby help moderate growth in peak electric demand, which is a main driver of the need for investments to upgrade the transmission and distribution system. LIPA will need to further expand on TOD rates with managed charging solutions in future years.
- Developing and implementing new or enhanced electric rate designs is crucial to managing the sales growth and peak demand from the electrification of transportation and heating.
- LIPA has introduced a standard offer Time-of-Day Rate to take effect in 2024. Most customers will be transitioned to this new rate in 2025.
- When customers choose to shift their usage to less costly times of the day, it decreases the amount of generation capacity and delivery infrastructure needed during peak times, reducing carbon emissions, and lowering system costs, with the cost savings passed back to customers through electric rates.

### Figure 30: Customer Bill Savings on the TOD Rate and Super Off-Peak Rates vs. the Flat Rate

	<b>TOD Rate</b> (Save before 3 p.m. or after 7 p.m.)	Super Off-Peak Rate (Smaller savings before 3 p.m. or after 7 p.m. and larger discounts between 10 p.m. and 6 a.m.)
Initial Savings (Before any Changes to Electric Use)	Save \$3.50 per month	Save \$5.75 per month
Dishwasher	Save \$0.50 per month	Save \$1.50 per month
Washing Machine	Save \$1.75 per month	Save \$4.50 per month
Electric Dryer	Save \$2.25 per month	Save \$6.00 per month
Pre-Cool Home (Before 3 p.m.)	Save \$12.75 per month (in the summer)	Save \$13.75 per month (in the summer)
Pool Pump	Save \$4.00 per month (in the summer)	Save \$6.50 per month (in the summer)
Battery Storage Optimized Use	Save \$40.00 per month	Save \$51.25 per month
Electric Vehicle	Save \$43.50 per month	Save \$56.50 per month
Total Savings (including changes)	`Save up to \$91.50 per month (\$108.25 in the summer)	`Save up to \$125.50 per month (\$147.75 in the summer)



- 7. Significant growth in electricity consumption is expected post-2030 as heating and transportation are increasingly electrified.
- The IRP estimates that changing customer usage patterns in response to TOD rates will result in a peak load reduction of 270 MW by 2030 or 6% of the total load.
- Beyond 2030, electrification will drive growth in the system's peak load. The effect can be mitigated if customers adopt smart EV charging practices, which LIPA is encouraging through TOD rates and future managed charging programs.
- Despite increasing electrification, the 2040 system peak is not expected to exceed the record peak of 5,915 MW experienced in July 2011.
- Additionally, while heating electrification will drive significant growth in winter peak load, LIPA is projected to remain a summer-peaking utility through 2040.



### Figure 29: Summer and Winter Peak Electric Demand Through 2040

- 8. Clean, distributed resources will transform the local electric grid into a two-way street, requiring upgrades in distribution capacity and controls, including the associated information technology systems to intelligently manage the grid.
  - LIPA will pursue federal grants for \$105 million toward \$210 million of upgrades to the distribution system to allow for additional interconnection capacity for distributed solar and storage (334MW of hosting capacity).
  - Develop new approaches to incorporate DER forecasts in planning for local feeder capacity
  - Deploy a DER Management System platform to monitor and manage DERs larger than 1 MW





## For the post-2030 period, the industry will need to develop new solutions and technology to balance electric supply

WHAT ARE THE KEY FINDINGS OF THE IRP?

9. and demand on an hourly, daily, and seasonal basis to fully replace dispatchable fossil units.

Climate Act-mandated additions of offshore wind and energy storage plus new interties to rest-of-state will be sufficient up to 2030

For the post-2030 period:

- Renewables and short-duration storage exhibit declining contribution to system reliability at high penetration levels
- Post-2030 mix of storage, renewables and dispatchable emissions-free resources (DEFRs) requires further study
- Research is already underway on DEFR technologies, including fuel cells and turbines that use biogas and hydrogen, modular nuclear units, and CO2 capture and sequestration



### Figure 19: Long Island Generation Capacity

Note: The chart does not include customer-owned solar and other behind-the-meter resources, which help to reduce the load that LIPA needs to serve



## MANAGING THE COSTS OF THE CLEAN ENERGY TRANSITION

- Most of the costs for the state's clean energy transition will be paid by electric load-serving entities, such as LIPA, according to their proportionate share of the statewide load.
- The changes in LIPA's Power Supply Charges between now and 2030 are relatively predictable (excluding volatile commodity prices) as we have reasonable cost estimates for much of the clean resource buildout that is currently under development and will be placed in service over the next seven years.
- As clean energy resources are added through 2030, LIPA estimates that the cost associated with transmission upgrades will grow from less than 10% of the Power Supply Charge today to over 50% by 2030. Much of these increases in clean energy costs will be offset by declining commodity costs and the associated cost of fossil-fueled infrastructure.
- Based on what we know today, the Power Supply Charge, which accounts for about half of LIPA's total electricity charge, is expected to grow at about 2% per year in real dollars through 2030, assuming reasonably stable commodity costs.



### Figure 34: Projected Power Supply Costs Through 2030



## NEXT STEPS

- The findings of the 2023 IRP offer a look at an evolving energy landscape of renewable technologies and decarbonization initiatives and illustrate how LIPA can meet and exceed the goals of New York's Climate Act while maintaining the two most critical aspects of service to customers – reliability and affordability.
- The energy landscape is certain to shift over the course of the next five years, and LIPA is well-positioned to navigate those changes.
- Follow-up studies to the IRP are currently underway, including:
  - Identifying any reliability deficiencies or operational concerns with expected generation retirements
  - Reviewing storage needs and identifying preferred Long Island and Rockaways points of interconnection
  - Establishing a new multi-year energy efficiency program
  - Reviewing the customer journey for EV and heat pump electrification and deploying new tools and programs to assist both customers and installers
  - Assessing projected resource margins for extreme weather events, including low renewable output, high summer temperatures, and increasing duration of heat waves
  - Completing the Climate Vulnerability Study and Resilience Plan



## **OPPORTUNITIES FOR PUBLIC PARTICIPATION**

- The public can participate in the IRP process by attending the informational sessions scheduled for Long Island and the Rockaways.
- LIPA is also accepting written comments from customers and stakeholders. Comments can be submitted via email to <u>IRP@lipower.org</u>. All comments will be taken into consideration by the LIPA Board of Trustees before any official adoption.
- 2024 public comment sessions:

### 1. Nassau Public Comment Session

Monday, February 12, 2024 | 6 p.m. \* Virtual participation available

### 2. Virtual Public Comment Session\*

Tuesday, February 13, 2024 | 10 a.m.

\* Virtual-Only (This session was originally scheduled for Suffolk County but was switched due to the pending weather forecast)

### 3. The Rockaways Public Comment Session

Thursday, February 15, 2024 | 6 p.m. Rockaway YMCA | 207 Beach 73rd St., Arverne, NY, 11692



# **Thank You**

We will now begin public comments.

